

Annual Drinking Water Quality Report **2019**

TOWN OF CONKLIN WATER DEPARTMENT

1271 Conklin Road; Conklin, New York
Public Water Supply I.D. Number NY0301660

INTRODUCTION

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is, and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is groundwater, which is withdrawn from the aquifer via two wells. The primary well (Well #6) is located on Terrace Drive. The second well (Well #5) is also located at the same facility. Both wells are treated at the Well #5 & #6 treatment plant on Terrace Drive. Treatment of the Town of Conklin water consists of disinfection with liquid chlorine, fluoridation, and the addition of an approved sequestering agent/pipe coating chemical called Aqua Mag.

A Source Water Assessment has been completed for our water system. A summary of this assessment has been completed by the Broome County Health Department and is attached to this report. A source water protection plan is available from our office that provides more information such as potential sources of contamination.

The Town of Conklin Water Department is pleased to report that our drinking water substantially meets federal and state requirements. The enclosed report shows our water quality and what it means. We want our valued customers to be informed about their water utility. If you have any questions about this report or concerning your water utility, please contact the Water Department at (607) 775-4584. If you want to learn more, please attend any of the Town Board's regularly scheduled meetings. They are held on the second Tuesday of every month, 7:00 p.m., at the Conklin Town Hall located at 1271 Conklin Road; Conklin, New York.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper, volatile organic compounds and disinfection byproducts. The table presented below

depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Broome County Health Department (607-778-2887).

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations, but we have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2019, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, we monitor fluoride levels on a daily basis to make sure fluoride is maintained at a target level of 0.7 mg/l. During 2019, monitoring showed that fluoride levels in your water were within 0.2 mg/l of the target level for greater than 90% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water substantially met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;

- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and

Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.

Turn off the tap when brushing your teeth.

Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.

Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

CONCLUSION

We at the Town of Conklin Water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office at (607) 775-4584 if you have questions regarding this document or the Town of Conklin Water System in general.

Annual Water Quality Report Certification Form

Water System Name: _____

Public Water Supply ID #: _____

The community water system named above hereby confirms that its Annual Water Quality Report (AWQR) has been distributed to customers and appropriate notices of availability have been given. Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the health department.

Certified by: Name: _____

Title: _____

Phone #: _____ Date: _____

Please indicate how your report was distributed to your customers:

- AWQR was distributed to bill-paying customers by mail.
- AWQR was distributed by other direct delivery method(s) (check all that apply)
 - Hand delivered.
 - Published in local paper (i.e., *Penny Saver*) that was directly delivered or mailed to all bill-paying customers.
 - Published in local municipal newsletter that was directly delivered or mailed.
 - Mailed a notification that AWQR is available on a public website via a direct URL
 - Emailed with a message containing a direct URL link to the AWQR
 - Emailed with AWQR sent as an attachment to the email
 - Emailed with AWQR sent as an embedded image in the email
 - Additional electronic delivery that meets “otherwise directly deliver” requirement
 - Other (please specify) _____
- System does not have bill-paying customers.
- For systems serving at least 100,000 persons:* in addition to direct delivery to bill-paying customer the AWQR was posted on a publicly-accessible website at [www._____](#)

Please indicate what “Good Faith” efforts were used to reach non-bill paying consumers (check all that apply).

- Posting the Annual Water Quality Report on the Internet at [www._____](#)
- Mailing the Annual Water Quality Report to postal patrons within the service area
- Advertising the availability of the Annual Water Quality Report in the news media
- Publication of the Annual Water Quality Report in a local newspaper
- Posting the Annual Water Quality Report in public places (attach a list of locations)
- Delivery of multiple copies to single-bill addresses serving several persons such as: apartments, businesses, and large private employers
- Delivery to community organizations
- Other (please specify) _____

INSTRUCTIONS

Annual Water Quality Report Certification Form

Community Water Systems must submit this Certification Form **by September 1st** of each year to the New York State Department of Health in Albany, NY and to the county or district health department office that has jurisdiction over the water system.

The certification must indicate how the water systems Annual Water Quality Report (AWQR) was distributed and that the information within the AWQR is correct and consistent with the compliance monitoring data previously submitted to the overseeing health department.

A copy of the AWQR (by 5/31/2020) and this Certification Form (by 9/1/2020) shall be submitted to the New York State Department of Health in Albany:

By mail to:

**NYS Department of Health
Corning Tower, Room 1110
Empire State Plaza
Albany, NY 12237**

Or electronically to:

AWQR@health.ny.gov

A copy of the AWQR (by 5/31/2020) and this Certification Form (by 9/1/2020) shall also be submitted to the Broome County Health Department:

**Peter Haff, P.G.
Groundwater Management Specialist
Broome County Health Dept.
225 Front Street
Binghamton, NY 13905**

Fax: 607-778-3912

phaff@co.broome.ny.us

Systems serving 1,000 or more service connections are required to send copy of AWQR (by 5/31/2020) to:

**NYS Department of Environmental Conservation
Attn: Director, Bureau of Water Permits
625 Broadway
Albany, NY 12207**

TABLE OF DETECTED CONTAMINANTS - CONKLIN

Contaminant	Violation Yes/No	Sample Location	Date of Sample	Level Detected (range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Barium	No	Wells 5 & 6 Entry Point	9/27/17	0.055	mg/l	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Lead ²	No	Distribution	9/2017	1.09 (ND-1.35)	ug/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
Copper ²	No	Distribution	9/2017	1.27 (0.137-1.32)	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Nitrate (as Nitrogen)	No	Wells 5 & 6 Entry Point	10/25/19	1.96	mg/l	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Fluoride	No	Wells 5 & 6 Entry Point	9/27/17	0.458	mg/l	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Sodium ³	No	Wells 5 & 6 Entry Point	10/25/19	33.3	mg/l	N/A	See Health Effects	Naturally occurring; Road salt; Water softeners; Animal waste.

Disinfection Byproducts

Total Trihalomethanes ⁴	No	Distribution	10/25/19	29.8	ug/l	N/A	80	By-product of drinking water chlorination.
------------------------------------	----	--------------	----------	------	------	-----	----	--

Notes:

2	The level presented represents the 90th percentile of the sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/copper values detected at your water system.
3	Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.
4	This level represents the total levels of the following contaminants: chloroform, bromodichloromethane, dibromochloromethane, bromoform.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Conklin Water Department
 NY0301660
 AWQR Source Water Assessment Summary

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells, called the well sensitivity. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected. While nitrate and other inorganic contaminants were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk.

As mentioned before, our water is derived from two drilled primary wells. The sensitivity of both wells is rated as high since they draw water from an unconfined productive aquifer that may not provide adequate protection from potential contamination. The source water assessment has rated these wells as having a medium-high susceptibility to microbial contaminants, such as enteric bacteria, enteric viruses and protozoa. These ratings are due primarily to the presence of unsewered residential areas in the vicinity of the wells. The assessment has also rated the wells as having a low to medium-high (specifically petroleum products due to the presence of tractor trailers in the vicinity) susceptibility to chemical contaminants as noted in the table below. A low susceptibility is warranted when no known source of a particular contaminant is identified in the capture zone of the well. While the source water assessment rates our wells as being moderately susceptible to microbials, please note that our water is disinfected to ensure that that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination.

SUSCEPTIBILITY TABLE		
CONTAMINANT	Well #5	Well #6
Cations/Anions	Low	Low
Enteric Bacteria	Medium-High	Medium-High
Enteric Viruses	Medium-High	Medium-High
Halogenated Solvents	Low	Low
Herbicides/Pesticides	Low	Low
Metals	Low	Low
Nitrate	Medium-High	Medium-High
Other Industrial Organics	Low	Low
Petroleum Products	Medium-High	Medium-High
Protozoa	Medium-High	Medium-High

The Town of Conklin currently has an active wellhead and watershed protection plan in place to ensure drinking water safety and the source water assessment is another tool that can help direct further refinements to the plan. County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs.

Annual Drinking Water Quality Report **2019**

TOWN OF CONKLIN WATER DISTRICT #6

1271 Conklin Road; Conklin, New York
Public Water Supply I.D. Number NY0330058

INTRODUCTION

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is, and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is groundwater supplied by the Town of Kirkwood which is piped under the Susquehanna River to supply Conklin Water District #6. The 2019 Annual Water Quality Report for the Town of Kirkwood is attached.

If you have any questions about this report or concerning your water utility, please contact the Water Department at (607) 775-4584. If you want to learn more, please attend any of the Town Board's regularly scheduled meetings. They are held on the second Tuesday of every month, 7:00 p.m., at the Conklin Town Hall located at 1271 Conklin Road; Conklin, New York.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for contaminants. These contaminants include total coliform and disinfection byproducts. The following compounds were detected in your drinking water:

Total Trihalomethanes, byproducts of chlorine disinfection, were collected on 10/25/2019 and detected at 12.1 ug/l which is below the Maximum Contaminant Level of 80 ug/l.

Haloacetic Acids, byproducts of chlorine disinfection, were collected on 10/25/2019 and were not detected in your drinking water.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2019, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

CONCLUSION

We at the Town of Conklin Water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office at (607) 775-4584 if you have questions regarding this document or the Town of Conklin Water System in general.

Annual Drinking Water Quality Report for 2019
Consolidated Water District No. 1
Town of Kirkwood
70 Crescent Drive
Kirkwood, New York 13795
(Public Water Supply ID #NY0311206)

INTRODUCTION

To comply with State regulations, Town of Kirkwood Consolidated Water District No. 1, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact the Town of Kirkwood, phone 607/775-1919. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Town board meetings.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is supplied from two groundwater wells near the Susquehanna River just South of Five Mile Point Plaza. During 2019, our system did not experience any restriction of our water source. The water supplied from the wells is constantly treated by air stripping and chlorination to safeguard against volatile organic contaminants, e-coli and coliform. A connection to the City of Binghamton water system is available for emergency use. No water was used from the City of Binghamton during this reporting period.

A source water assessment has been completed by a private consultant sponsored by the New York State Department of Health. The complete report is available for your review. A summary prepared by the Broome County Health Department has been attached.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, residual chlorine, inorganic compounds, nitrate, lead and copper, volatile organic compounds, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

In addition, the NYSDOH performed special sampling on October 26, 2017. The sample results indicate that extremely low levels of perfluorinated compounds were present in the finished water. Specifically, Perfluorooctanoic Acid (PFOA) was detected at 3.26 ng/l (parts per trillion) and Perfluorooctanesulfonic Acid (PFOS) was detected at 1.98 ng/l. These values are well below the USEPA advisory value of 70 ng/l and the proposed NYS MCL of 10 ng/l..

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Broome County Health Department at 778-2887.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements. It should be noted that the action level for lead was not exceeded in any of the samples collected; however, we are required to present the following information on lead in drinking water:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Kirkwood Consolidated Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2019, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- 1 Saving water saves energy and some of the costs associated with both of these necessities of life.
- 2 Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- 3 Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your house holds using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- 1 Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- 2 Turn off the tap when brushing your teeth.
- 3 Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- 4 Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

Kirkwood Consolidated Water District #1
 NY0311206
 AWQR Source Water Assessment Summary

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected. While nitrate and other inorganic contaminants were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk.

As mentioned before, our water is derived from two drilled wells. The source water assessment has rated these wells as having a high susceptibility to chemical and microbial contaminants as noted in the table below. These ratings are due primarily to the proximity to the wells of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) hazardous waste sites and Toxic Release Inventory sites. In addition, the wells draw from an unconfined aquifer that may not provide adequate protection from potential contamination. Halogenated solvents have been historically documented as impacting the well field. While the source water assessment rates our wells as being highly susceptible to microbials, please note that our water is disinfected to ensure that that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination.

SUSCEPTIBILITY TABLE		
CONTAMINANT	WELL #1	WELL #3
Cations/Anions (Salts)	High	High
Enteric Bacteria	High	High
Enteric Viruses	High	High
Halogenated Solvents	High	High
Herbicides/Pesticides	High	High
Metals	High	High
Nitrate	High	High
Other Industrial Organics	High	High
Petroleum Products	High	High
Protozoa	High	High

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the assessment, including a map of the assessment area, can be obtained by contacting the water supplier.

TABLE OF DETECTED CONTAMINANTS 2019

Contaminant	Violation Yes/No	Sample Location	Date of Sample	Level Detected (range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Barium	No	Well #1 Well #3	6/10/2019 6/10/2019	0.0325 0.0278	mg/l	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Lead ²	No	Distribution	9/27/2017	1.48 (ND-2.41)	ug/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
Copper ²	No	Distribution	9/27/2017	0.146 (0.0256-0.164)	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Nitrate (as Nitrogen)	No	Well #1 Well #3	6/10/2019 6/10/2019	0.517 0.637	mg/l	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium ³	No	Well #1 Well #3	6/10/2019 6/10/2019	49.7 36.9	mg/l	N/A	See Health Effects	Naturally occurring; Road salt; Water softeners; Animal waste.
Disinfection Byproducts								
Total Trihalomethanes ⁴	No	Distribution	8/28/2019	22.3	ug/l	N/A	80	Byproduct of drinking water chlorination.
Radiological Contaminants								
Gross Beta	No	Well #1 Well #3	7/24/2017 7/24/2017	0.885 0.896	pCi/L	0	50	Decay of natural deposits and man-made emissions.
Radium 226	No	Well #1 Well #3	7/24/2017 7/24/2017	0.409 0.257	pCi/L	0	5	Erosion of natural deposits.
Radium 228	No	Well #1 Well #3	7/24/2017 7/24/2017	0.243 0.393	pCi/L	0	5	Erosion of natural deposits.
Notes:								
2	The level presented represents the 90th percentile of the sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/copper values detected at your water system.							
3	Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.							
4	This level represents the total levels of the following contaminants: chloroform, bromodichloromethane, dibromochloromethane, bromoform.							
Definitions:								
Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.								
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.								
Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.								
Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.								
Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).								
Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).								
Picocuries per liter (pCi/L): A measure of the radioactivity in water.								

Kirkwood Consolidated Water District #1
 NY0311206
 AWQR Source Water Assessment Summary

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected. While nitrate and other inorganic contaminants were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk.

As mentioned before, our water is derived from two drilled wells. The source water assessment has rated these wells as having a high susceptibility to chemical and microbial contaminants as noted in the table below. These ratings are due primarily to the proximity to the wells of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) hazardous waste sites and Toxic Release Inventory sites. In addition, the wells draw from an unconfined aquifer that may not provide adequate protection from potential contamination. Halogenated solvents have been historically documented as impacting the well field. While the source water assessment rates our wells as being highly susceptible to microbials, please note that our water is disinfected to ensure that that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination.

SUSCEPTIBILITY TABLE		
CONTAMINANT	WELL #1	WELL #3
Cations/Anions (Salts)	High	High
Enteric Bacteria	High	High
Enteric Viruses	High	High
Halogenated Solvents	High	High
Herbicides/Pesticides	High	High
Metals	High	High
Nitrate	High	High
Other Industrial Organics	High	High
Petroleum Products	High	High
Protozoa	High	High

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the assessment, including a map of the assessment area, can be obtained by contacting the water supplier.